

EC-Certificate of Conformity

Certificate No. 0086-CPD-587752

In compliance with Council Directive 89/106/EEC of 21 December 1988 on the approximation of laws, regulations and administrative provisions of the Member States relating to construction products (the Construction Products Directive or CPD), as later amended, it has been stated that the construction product

Point Type Smoke Detectors

as detailed on the Supplementary Information Sheet

placed on the market by

Ningbo Ambest Electronics Co. Ltd

Huangsu West Road, Industrial Zone of Dongqianhu Tourist Resort District, Ningbo, Zhejiang,
315121, China

and produced in the factories at

Huangsu West Road, Industrial Zone of Dongqianhu Tourist Resort District, Ningbo, Zhejiang,
315121, China

is submitted by the manufacturer to a factory production control and that the notified body 0086 BSI has performed the initial type-testing for the relevant characteristics of the product, the initial inspection of the factory and of factory production control and performs the continuous surveillance, assessment and approval of factory production control.

This certificate attests that all provisions concerning the attestation of conformity and the performances described in Annex ZA of the standard(s)

EN 54-7:2001 + A1 & A2

were applied.

This certificate remains valid as long as the conditions laid down in the harmonised standard in reference or the manufacturing conditions in the factory or the FPC itself are not modified significantly.

For and on behalf of BSI, a Notified Body for the above Directive (Notified Body Number 0086).



Gary Fenton, Global Assurance Director

First Issued: 06 June 2013

Page 1 of 2

Latest Issue: 19 June 2013

...making excellence a habit.™

SUPPLEMENTARY INFORMATION SHEET
Certificate No. 0086-CPD-587752
Ningbo Ambest Electronics Co. Ltd

Product Information

Model Reference	Type
SNC-300-S2	Conventional 2 Wire Photoelectric Smoke Detector
SNC-300-SL	Conventional 2 Wire Photoelectric Smoke Detector with Remote Indicator
SNC-300-SR	Conventional 4 Wire Photoelectric Smoke Detector with Relay Output

Certified for use with the CN3023 and CN3043 detector mounting base

